



BIHAR STATE POLLUTION CONTROL BOARD

Parivesh Bhawan, Patliputra Industrial Area, Patna-800 010

EPABX-0612-2281250/2282265, Fax-0612-2281050

E-mail-bspccb@yahoo.com, Website-http://bspccb.bih.nic.in

Ref. No.

Patna, dated:-

From

Alok Kumar,
Member Secretary.

To,

M/s Globus Spirits Ltd.,
Vill-Dhudhua, Jandaha,
Dist-Vaishali-844505.

Sub: Compliance of Directions.

- Ref:**
1. Direction under section 33A of the Water (Prevention and Control of Pollution) Act, 1974 issued vide Board's letter no. B-1757, dated-22.11.2018 & further vide letter no. 334, dated-22.02.2019 and
 2. Direction under section 5 of the Environment (Protection) Act, 1986 issued by CPCB vide its letter dated-06.02.2019.

Sir,

Kindly refer to the subject and references cited above. In this regard it is to inform that your unit was inspected by NIT team on 21.06.2018 and it was found closed. CPCB issued direction under section 18 (1) (b) to this Board vide its letter no. 19004/WQM-II/CPCB/2018-19/11723, dated-22.10.2018 to issue direction to all temporarily/permanently closed units under the Water Act, 1974 to remain closed and not to resume operations till their compliance with discharge and emission norms are ensured & permission by BSPCB is granted.

2. In compliance of the aforesaid direction, Bihar State Pollution Control Board directed the unit (M/s Globus Spirits Ltd., Jandaha, Dist-Vaishali) vide letter no. B-1757, dated-22.11.2018 to remain closed and not resume its operation till compliance verification and fresh permission from BSPCB is obtained.
3. The unit was further inspected on 06.02.2019 by Board's officials and following were observed:-
 - a. The unit was found operational without maintaining Zero Liquid Discharge (ZLD).
 - b. The unit has an ETP system which includes collection tank, USAB/Bio-tower, aeration tank, clarifier, incomplete sludge drying beds, MGF & ACF. The USAB/Bio-tower, clarifier, sludge drying beds, MGF & ACF of the ETP system were not in line of treatment. Only aeration tank was operational without sludge formation/MLSS.

- c. The unit has installed online stack emission monitoring system for particulate matter but not connected with CPCB server.
 - d. The unit has not installed mass flow meter at MEE feed and MEE concentrate outlet as required in compliance with CPCB guidelines for maintaining ZLD.
 - e. There is no plantation inside the premises.
 - f. Internal roads are kachcha and under development.
 - g. The unit is discharging its effluent inside the premises and not maintaining ZLD.
 - h. Logged water was observed in farmer's agricultural land in east side after boundary due to seepage/discharge from premises. It indicates that the complaint made against the unit is genuine.
 - i. The representative of the unit was not aware regarding the mandatory permission required from CGWA for extraction of ground water indicating perhaps there was no permission.
 - j. The unit has not complied with the direction of this Board given under section 33A of the Water (Prevention and Control of Pollution) Act, 1974 as well as conditions of CTOs granted by the Board.
4. As such BSPCB has issued direction to the District Magistrate, Vaishali vide letter no. 334, dated-22.02.2019 to ensure closure of the unit in terms of CPCB direction to the BSPCB (Copy enclosed).
5. CPCB has also issued direction to the District Magistrate, Vaishali vide its letter dated-06.02.2019 to ensure that the closure direction issued under section 33A of the Water Act, 1974 by this Board be complied forthwith and ensure that unit does not operate till permission is granted by BSPCB. (Copy enclosed).

In view of the above you are directed to comply with the aforesaid directions issued by BSPCB & CPCB, conditions of CTOs previously granted and take measures regarding the shortcomings observed during the inspection and ensure develop/installation of all systems for maintenance of ZLD.

Encl: as above.

Memo no: B-1200

Copy to: Legal Cell/Concerned R.O., BSPCB for information and necessary action.


Yours faithfully,

Sd/-

(Alok Kumar)

Member Secretary

Patna, Dated: 26/2/19



26/2/19

(Alok Kumar)

Member Secretary