

31/01/2021-04

12/3/2021

Notification

As per office memorandum no.- B-13011/1/2019-20/AQM-10809, dated 07.01.2020 and a fresh guidelines dated 16.01.2020 of Central Pollution Control Board, Govt. Of India, Delhi in the light of Direction issued by Hon'ble National Green Tribunal and as per the notification of Ministry of Petroleum & Natural Gas, Govt. Of India, by notification no-GSR728(E), dated 29.06.2017, guidelines for setting up of new petrol pumps (retail outlets) and new bio-diesel outlets for the siting criteria with the permission of competent authority are approved as follow:-

Sl. no	Industry Sector	Habitation (Not less than 200 permanent dwellers)	School (Govt. or Registered from any Govt. organisations)	Hospital (Govt. or Registered from any Govt. organisations) having ten beds and above.
1.	New Petrol pumps (Retail outlets) and New Bio-Diesel Retail outlets	50M	50M	50M


- All Retail outlets have to comply with the guidelines submitted by the Expert committee of the Central Pollution Control Board, Govt. of India, Delhi (Enclosed).
- All retail outlets of oil companies have to install the vapour Recovery system (VRS) at all those stations where about 300KL/Month Oil is sold.
- The owner of every outlet selling Bio-Diesel (B-100), shall prominently display at the place of business the "Permissible limits" specified by the manufacturers of vehicles and the standards specified by the Bureau of Indian standards for blending of bio-diesel (B-100) for use of consumers in their vehicles.

Sd/-
(S. Chandrasekar)
Member Secretary

Memo No. 577

Patna, dated: 12-3-2021

Copy to: B.A/All EEs/All Regional Officers/Scientific Advisor, BSPCB/ M.S.
Cell for information and necessary action.


(S. Chandrasekar)
Member Secretary
12/3/21